

Solicitation #: RFX #: 3160006430

Date: 3/13/2024

**Department of Finance and Administration
Amendment #1: Question and Answer – Responses
HVAC Water Treatment Services Invitation for Bids**

Question #	Section #	Page #	Question	DFA Response
1	3.1.5 "B"	15	In the event automatic chemical feeders are needed to provide chemicals to an open loop, will we need to include that cost in our bid, or will the current equipment be left on site?	Yes, DFA Confirms the cost of automatic chemical feeders shall be included with any submitted bid.

Receipt of Amendment #1 Acknowledged:

Company: _____

By: _____

Printed: _____

Title: _____